

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Kenneth Schermerhorn, Asst. Fire Inspector

SUBJECT: PB-09-13
Dunkin Donuts
SBL: 33-2-4

DATE: February 26, 2009

Fire Prevention Reference Number: FPS-09-014

A review of the above referenced site plan has been conducted and is disapproved for the following reasons:

- 1) Insufficient Fire Lane - 30 ft. required.
- 2) Insufficient access at curb.