

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Kenneth Schermerhorn, Asst. Fire Inspector

**SUBJECT: Silver Stream Properties, LLC
SBL: 3-1-35**

DATE: October 22, 2007

Fire Prevention Reference Number: FPS-07-022

A review of the above referenced site plan has been conducted and is disapproved for the following reasons:

- 1) Needs hydrant in vicinity of sprinkler Siamese and a second hydrant on opposite side near loading dock.**

*** Note: Bldg. needs a sprinkler system with associated alarm.**