



**McGOEY, HAUSER and EDSALL  
CONSULTING ENGINEERS P.C.**

RICHARD D. McGOEY, P.E. (NY & PA)  
WILLIAM J. HAUSER, P.E. (NY & NJ)  
MARK J. EDSALL, P.E. (NY, NJ & PA)  
JAMES M. FARR, P.E. (NY & PA)

**MAIN OFFICE**  
33 Airport Center Drive  
Suite 202  
New Windsor, New York 12553

(845) 567-3100  
fax: (845) 567-3232  
e-mail: mheny@mhepc.com

*Writer's e-mail address:*  
*JSzarowski@mhepc.com*

**TOWN OF NEW WINDSOR  
PLANNING BOARD  
SWPPP TECHNICAL REVIEW COMMENTS**

**PROJECT NAME: SILVER STREAM PROPERTIES**  
**PROJECT LOCATION:**  
**P.B. PROJECT NO.: 07-29**  
**APPLICANT'S REPRESENTATIVE: MASER**  
**PREPARATION DATE: 10 MARCH 2008**  
**MEETING DATE:**

Our office has reviewed the Stormwater Pollution Prevention Plan (SWPPP), revised February 2008, with regard to the subject project. Upon our review of the aforementioned revised SWPPP, we find the plan to be in substantial compliance with the New York State Department of Environmental Conservation "SPDES" General Permit for Stormwater Discharges from Construction Activities, Permit GP-02-01. As such, this office takes no exception to the SWPPP as submitted with the following conditions:

1. Catch Basins are required to have a 12-inch sump per Town of New Windsor standard details and are considered a Best Management Practice by the NYSDEC. Applicant to include sumps in all proposed catch basins.

Respectfully submitted,

**MCGOEY, HAUSER & EDSALL  
CONSULTING ENGINEERS, P.C.**

  
\_\_\_\_\_  
John Szarowski, P.E.  
Senior Engineer

**REGIONAL OFFICES**

- 111 Wheatfield Dr. – Suite One • Milford, Pennsylvania 18337 • 570-296-2765 •
- 540 Broadway • Monticello, New York 12701 • 845-794-3399 •