

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman
FROM: Kenneth Schermerhorn, Asst. Fire Inspector *KS*
SUBJECT: PB-04-27
Ridge Rise
SBL: 35-1-112
DATE: October 13, 2006

Fire Prevention Reference Number: FPS-06-046

A review of the above referenced site plan has been conducted and is disapproved for the following reasons:

- 1) Items # 2 & 5 have not been corrected from review dated 10-6-04**
- 2) Need to show hydrant locations**
- 3) Proposed gate to Washington Green to be removed**

*** Please see enclosed copy of site plan review done 10-06-04**