

TOWN OF NEW WINDSOR

555 Union Avenue
New Windsor, New York 12553
Telephone: (845) 563-4610
Fax: (845) 563-4693

OFFICE OF THE INFRASTRUCTURE COMMITTEE

PROJECT REVIEW SHEET

TO: PLANNING BOARD

P.B. FILE:01-44

DATE RECEIVED:

TAX MAP #:65-2-1.1
65-2-1.2
65-2-3

THE MAPS AND/OR PLANS FOR: **COVINGTON ESTATES**

Applicant or Project Name:

SITE PLAN **X**, SUBDIVISION , LOT LINE CHANGE ,
SPECIAL PERMIT

HAVE BEEN REVIEWED BY THE UNDERSIGNED AND ARE:

NO RECOMMENDATIONS:

X RETURN TO PLANNING BOARD WITH THE FOLLOWING RECOMMENDATIONS:

Water: need contribution towards water.

Sewer: need to mitigate conditions to enter sewer line. They do not have rights to tie into the 30" and there are problems with capacity in the 12".

Need to contribute towards infrastructure upgrades for the 30" main into the 15" at the plant.

Signature: George C. Sisco 8/8/07
Reviewed by: _____ Date: _____

cc: Jerry Argenio, Planning Board Chairman
Dominic Cordisco, Planning Board Attorney
Mark J. Edsall, Planning Board Engineer
Michael Babcock, Building Inspector