

INTER-OFFICE CORRESPONDENCE

TO: Town Planning Board

FROM: Town Fire Inspector

SUBJECT: Patriot Bluff Condominiums

DATE: December 10, 2001

Planning Board Reference Number: PB-01-65

Dated: 6 December 2001

Fire Prevention Reference Number: FPS-01-068

A review of the above referenced subject project was conducted on 7 December 2001, with the following being noted:

- 1) There should be two direct access routes to this project. The emergency access control should be removed from the Park Hill Drive entrance, so that there is always two (2) way access to this Condominium project.**

This development plan is not acceptable.

Plans Dated: 3 December 2001.

RFR (D.H.)
Robert F. Rodgers