



**McGOEY, HAUSER and EDSALL  
CONSULTING ENGINEERS P.C.**

RICHARD D. MCGOEY, P.E. (NY & PA)  
WILLIAM J. HAUSER, P.E. (NY & NJ)  
MARK J. EDSALL, P.E. (NY, NJ & PA)  
JAMES M. FARR, P.E. (NY & PA)

**MAIN OFFICE**  
33 Airport Center Drive  
Suite 202  
New Windsor, New York 12553

(845) 567-3100  
fax: (845) 567-3232  
e-mail: mheny@mhepc.com

*Writer's e-mail address:*  
JSzarowski@mhepc.com

**TOWN OF NEW WINDSOR**  
**PLANNING BOARD**  
**SWPPP TECHNICAL REVIEW COMMENTS**

**PROJECT NAME:** RUTHIES  
**PROJECT LOCATION:**  
**P.B. PROJECT NO.:** 07-26  
**APPLICANT'S REPRESENTATIVE:** FINE & ASSOCIATES  
**REVIEW DATE:** 7 APRIL 2009

We are in receipt of the revised Stormwater Pollution Prevention Plan report, revised 10 February 2009. Upon our review of the aforementioned revised SWPPP, we summarily reject the SWPPP as submitted for the following reasons:

1. Town of New Windsor, Chapter 249, Stormwater Management and Stormwater Pollution Prevention require that minimum standards be met regarding stormwater. Per Town Code, stormwater management and stormwater pollution prevention plan must comply with the requirements of the NYSDEC construction SPDES permit and New York State Stormwater Management Design Manual. Stormwater management plans must address water quantity control as well as water quality control including storage requirements for water quality volume, stream protection, ten-year peak runoff control and a one-hundred-year flood control, in addition, detention ponds shall also be analyzed for a twenty-five-year storm event for a pre- and post-development runoff analysis.
2. As submitted the SWPPP does not address stormwater quantity for the channel protection, 10, 25 and 100 year storms. Paving an entire site such that there is insufficient land available for stormwater quantity management does not alleviate an applicant from Town Code.
3. Please refer to NYSDEC SPDES General Permit for Stormwater Discharges from Construction Activity for minimum components to be included in a Stormwater Pollution Prevention Plan and Report.

Once the above items are addressed, a more complete review of the SWPPP will be undertaken.

Respectfully submitted,

**MCGOEY, HAUSER & EDSALL  
CONSULTING ENGINEERS, P.C.**

John Szarowski, P.E., CPESC, CPSWQ, LEED-AP  
Senior Engineer

**REGIONAL OFFICES**

- 111 Wheatfield Dr. – Suite One • Milford, Pennsylvania 18337 • 570-296-2765 •
- 540 Broadway • Monticello, New York 12701 • 845-794-3399 •